

TABULKA 5

<i>Středočeské vodárny, a.s. Kanalizační řád Kralupy nad Vltavou</i>		Kaučuk I	Kaučuk II	Balak	Nowaco	NES	ubytovna Viktor
<i>Max. Q a znečištění OV</i>		max.	max.	max.	max.	max.	max.
		1	2	3	4	5	6
Q (celk. roční průměr)	m ³ /r	450 000	1 750 000	52 000	17 000	20 000	10 000
Q (celk. roční průměr)	m ³ /d	1 233	4 795	142	47	55	27
Q (celk. roční průměr)	l/s	14	55.0	1.6	0.5	0.6	0.3
Q (OV faktur.2004)	m ³ /r	285 629	1 207 074	45 649	13 504	16 465	7 895
Q (OV faktur.2004)	m ³ /d	783	3 307	125	37	45	22
Q (OV faktur.2004)	l/s	9	38	1	0	1	0.3
BSK5	t/r	113	350	16	14	6	8.0
BSK5	kg/d	308	959	43	37	16	22
BSK5 (průměr)	mg/l	250	200	300	800	300	800
BSK5 (max.)	mg/l	800	500	450	1 200	450	1200
CHSK	t/r	225	1 050	31	14	12	8.0
CHSK	kg/d	617	2 877	85	37	33	22
CHSK (průměr)	mg/l	500	600	600	800	600	800
CHSK (max.)	mg/l	1 600	1 800	800	1 000	900	1 000
NL	t/r	90	350	8	8	6	4.5
NL	kg/d	247	959	23	21	16	12
NL (průměr)	mg/l	200	200	160	450	300	450
NL (max.)	mg/l	900	600	250	500	450	500
N-NH4+	t/r	5	18	1	1	0	0.2
N-NH4+	kg/d	12	48	2	2	1	0
N-NH4+ (průměr)	mg/l	10	10	15	40	10	15
N-NH4+ (max.)	mg/l	20	45	20	45	15	45
Nc	t/r	9	26	1	1	0	0.4
Nc	kg/d	25	72	3	3	1	1
Nc (průměr)	mg/l	20	15	20	55	15	40
Nc (max.)	mg/l	40	60	25	60	20	50
Pc	t/r	5	9	0	0	0	0.1
Pc	kg/d	12	24	0	0	0	0
Pc (průměr)	mg/l	10	5	3	8	8	8
Pc (max.)	mg/l	15	10	5	10	10	10
RAS	t/r	585	3 150	47	20	24	12
RAS	kg/d	1 603	8 631	128	56	66	33
RAS (průměr)	mg/l	1 300	1 800	900	1 200	1 200	1200
RAS (max.)	mg/l	2 500	4 000	1 200	1 400	1 400	1400
NEL	t/r	2	18				
NEL	kg/d	6	48				
NEL (průměr)	mg/l	5	10				
NEL (max.)	mg/l	15	30				
vodohospod. aktivita	dny/rok	365	365	260	365	260	365
vodohospod. aktivita	hod/den	24	24	8	24	12	24

TABULKA 6

<i>Středočeské vodárny, a.s.</i> <i>Kanalizační řád</i> <i>Kralupy nad Vltavou</i>		odběratelé č.7 (kap. 11.3.) max.	odběratelé č.8.1- 8.7. (kap. 11.3.) max.	odběratelé č.8.8.- 8.16. (kap. 11.3.) max.
<i>Max. Q a znečištění OV</i>		<i>7</i>	<i>8a</i>	<i>8b</i>
Q (celk. roční průměr)	m ³ /r	2 000	35 000	65 000
Q (celk. roční průměr)	m ³ /d	5	96	178
Q (celk. roční průměr)	l/s	0.1	1.1	2.1
Q (OV faktur.2004)	m ³ /r	500	29 961	54 867
Q (OV faktur.2004)	m ³ /d	1	82	150
Q (OV faktur.2004)	l/s	0.0	1.0	1.7
BSK5	t/r	1	28	52
BSK5	kg/d	3	77	142
BSK5 (průměr)	mg/l	600	800	800
BSK5 (max.)	mg/l	900	1200	1200
CHSK	t/r	2	42	78
CHSK	kg/d	7	115	214
CHSK (průměr)	mg/l	1200	1200	1200
CHSK (max.)	mg/l	1600	1600	1600
NL	t/r	0	11	20
NL	kg/d	1	29	53
NL (průměr)	mg/l	200	300	300
NL (max.)	mg/l	400	500	500
N-NH4+	t/r	0.0	1.1	2.0
N-NH4+	kg/d	0.1	2.9	5.3
N-NH4+ (průměr)	mg/l	20	30	30
N-NH4+ (max.)	mg/l	40	45	45
Nc	t/r	0.1	1.2	2.3
Nc	kg/d	0.1	3.4	6.2
Nc (průměr)	mg/l	25	35	35
Nc (max.)	mg/l	45	50	50
Pc	t/r	0.0	0.4	0.7
Pc	kg/d	0.0	1.0	1.8
Pc (průměr)	mg/l	8	10	10
Pc (max.)	mg/l	10	15	15
RAS	t/r	2	32	59
RAS	kg/d	5	86	160
RAS (průměr)	mg/l	900	900	900
RAS (max.)	mg/l	1200	1200	1200
NEL	t/r	0.0		
NEL	kg/d	0.0		
NEL (průměr)	mg/l	9		
NEL (max.)	mg/l	10		
vodohospod. aktivita	dny/rok	365	250 – 365	250 – 365
vodohospod. aktivita	hod/den	24	8 – 24	8 – 24